

PROFORMA FOR SAFE SANITARY CONDITION CERTIFICATE

L.Dis.No:8520/A6/2026

Office of the District Health Office
"B" Block, IIInd Floor, Sathuvachari
Vellore – 632 009 Dated:25.09.2026


It is Certified that an Inspection team headed by District Health Office inspected the **BHARATHIDHASANAR PUBLIC SCHOOL, SURVEY NO:62/3, BOMMINAYAKKAN PALAYAM VILLAGE, K.V.KUPPAM TALUK, VELLORE DISTRICT – 632202** on **25.09.2026** and Certify found that the **BHARATHIDHASANAR PUBLIC SCHOOL** has safe drinking water facilities for the students of Pre KG to VIII Standard and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the State Government (Chapter III Rule : 24) Tamil Nadu Education Rules.

"No Smoking area – Smoking her is an offence" and "Sale of Tobacco Products around 100 yards of this institution is banned" and complying with the provisions already prescribed for Smoke Free Educational Institutions and that in all other necessary respects the sanitation is

: This Certificate Valid for One year from the date of issue.



Signature with Seal:


DISTRICT HEALTH OFFICER
VELLORE DISTRICT - 632 009.

Name: Dr.M.VIJAYCHANDRAN, MBBS, DPH, DIH.,

Designation : District Health Officer

Name and Address of the Office / Department: District Health
Office, Vellore-632 009

To

Bharathidhasanar Public School,
Bomminayakkan Palayam Village,
K.V.Kuppam Taluk,
Vellore District - 632 202


PRINCIPAL

BHARATHIDHASANAR PUBLIC SCHOOL
B.N. PALAYAM, K.V.KUPPAM TALUK,
VELLORE DISTRICT-632 202


MANAGER

BHARATHIDHASANAR PUBLIC SCHOOL
B.N. PALAYAM, K.V.KUPPAM TALUK,
VELLORE DISTRICT-632 202.



TEST REPORT

Doc. No: DWTL/FORM/7.8/01

Doc No: DWLF/FORM/7.8/01

Report No.	TR/2026/67944	Report Issue Date	28.09.2026	Page No: 01 of 02
Invoice Details	11871/ dt:25.09.2026	ULR. No.	TC16337260000000044F	
Client Name & Address Contact o./Email.ID	Bharathidhasanar Public School, BN palayam Village. KV Kuppam Taluk. Vellore District-632202			
Sample Submitted by	Babu			
Sample Location	Bharathidhasanar Public School			
Sample Description	Clear Colorless Liquid			
Sample Name	Water	Sample Source	:	Bore well
Sample/Lab No.	2026/67944	Sample Container	:	Plastic – Good
Quantity of sample Received	2 lit	Sample Condition	:	Good
Sample Received on	25.09.2026	Temperature / Humidity %	:	25°C / 50%
Test Commenced on	25.09.2026	Test Completed on	:	26.09.2026

No	Parameters	Test Method	Unit	Result (2026/67944)	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
	Colour	IS3025:Part4: 2021	Hazen	<1	5	15
	Odour	IS3025:Part5: 2018	--	Agreeable	Agreeable	Agreeable
	Taste	IS3025:Part8: 2023	--	Agreeable	Agreeable	Agreeable
	Turbidity	IS3025:Part10: 2023	NTU	< 0.5	1	5
	pH@25°C	IS3025: Part11: 2022	--	6.52	6.5-8.5	No Relaxation
	Total Dissolved Solids	IS3025:Part16: 2023	mg/L	46	500	2000
	Total Alkalinity as CaCO ₃	IS3025: Part23: 2023	mg/L	16	200	600
	Total Hardness as CaCO ₃	IS3025: Part21:2009 (RA:2023)	mg/L	36	200	600
	Calcium as Ca	IS3025:Part40: 2024	mg/L	7	75	200
	Magnesium as Mg	IS3025:Part46: 2023	mg/L	4	30	100
	Chloride as Cl	IS3025:Part32: 1988(RA:2019)	mg/L	9	250	1000
	Nitrate as NO ₃	APHA 24 th Edn – 4500 – NO ₃ – B – 2023 (Screening Method)	mg/L	<0.2	45	No Relaxation
	Fluoride as F	APHA 24 th Edn – 4500 – F – D – 2023 (Spadns Method)	mg/L	<0.2	1.0	1.5
	Sulphate as SO ₄	APHA 24 th Edn – 4500 – SO ₄ E – 2023 (Turbidimetric Method)	mg/L	5	200	400

Remark: The sample is conform to IS: 10500:2012(RA:2023) Drinking Water Acceptable Limit / Permissible specification with respect to above tested parameters of Physical & Chemical.

PRINCIPAL

BHARATHIDHASANAR PUBLIC SCHOOL
B.N. PALAYAM, K.V.KUPPAM TALUK,
VELLORE DISTRICT-632 202

MANAGER

BHARATHIDHASANAR PUBLIC SCHOOL
B.N PALAYAM K.V.KUPPAM TALUK,
VELLORE DISTRICT-632 202.

B. S. Narendran
 28/9/26
Authorized Signatory
M.S. NARENDIRAN, M.Sc
Junior Water Analyst
DWTL - Vellore

The test results shall be valid only on the basis of the sample as received basis.

The test items will not be retained for more than 15 days from the date of issue of the test report

DL: Below Detection Limit; DI: Detection Limit; NT: Not Tested (Bacteriologically unsafe)

The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

.....End of the Report.....

Issue No./Date	01/10.01.2021	Amend. No./Date	01/02.01.2026	Page No.	1 of 2
----------------	---------------	-----------------	---------------	----------	--------



DISTRICT WATER TESTING LABORATORY
Opp. Muthu Mandapam, Old Katpadi Road, Vellore.632 004
Phone: 0416-2215168. E-Mail: twadlabphotos2021@gmail.com

TEST REPORT

Doc. No: DWTL/FORM/7.8/01

Report No.	TR/2026/67944A	Report Issue Date	28.09.2026	Page No: 02 of 02
Invoice Details	11871 dt:25.09.2026			

S. No	Parameters	Test Method	Unit	Result (2026/67944 A)	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	P. Alkalinity as CaCO ₃	IS3025:Part23: 2023	mg/L	Zero	--	--
2	Manganese as Mn	IS3025(Part59) : 2023	mg/L	0.0	0.1	0.3
3	Ammonia as NH ₃ -N	IS3025(Part34) : 2019	mg/L	0.0	0.5	No relaxation
4	Nitrite as NO ₂	IS3025(Part34/Sec-1) :2023	mg/L	0.0	--	--
5	Iron	APHA 23rd Edition 2017-3500 Fe B	mg/L	0.0	0.3	1.0
6	Phosphate as PO ₄	IS3025(Part31/Sec-1) :2022	mg/L	0.0	0.0	0.0
7	Residual Chlorine	IS/APHA	mg/L	0.0	0.2	1.0

Bacteriological Test

1	Total Coliform	IS 15185: 2016 (RA: 2021)	CFU	Absence	Absence / 100 mL
2	Fecal Coliform	IS 15185: 2016 (RA: 2021)	CFU	Absence	Absence / 100 mL

Remark:

The Tested sample conform to IS: 10500:2012(RA:2023) Drinking Water Acceptable Limit / Permissible Limit specification with respect to above tested parameters of Chemical.

The Tested sample conform to IS: 10500:2012(RA:2023) Drinking Water Acceptable Limit / Permissible Limit specification with respect to above tested parameters of Bacteriological.


PRINCIPAL
BHARATHIDHASANAR PUBLIC SCHOOL
B.N. PALAYAM, K.V.KUPPAM TALUK,
VELLORE DISTRICT-632 202.


MANAGER
BHARATHIDHASANAR PUBLIC SCHOOL
B.N. PALAYAM, K.V.KUPPAM TALUK,
VELLORE DISTRICT-632 202.

The test results relate only to the items tested.

The result applied to the sample as received basis.

The test items will not be retained for more than 15 days from the date of issue of the test report

DL: Below Detection Limit; **DL:** Detection Limit; **NT:** Not Tested (Bacteriologically unsafe)

The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

.....End of the Report.....

Issue No./Date	01/10.01.2021	Amend. No./Date	01/02.01.2026	Page No.	2 of 2
----------------	---------------	-----------------	---------------	----------	--------


Authorized Signatory
M.S. NARENDIRAN, M.Sc
Junior Water Analyst
DWTL - Vellore